



# CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 131202 - E227244

ISSUE DATE: 12-13-2002

Page 1 of 1

Issued to: Oemer Motori Elettrici S.p.A.  
Via Legnano 41  
I-20027 Rescaldina (MI) Italy

Report Reference: E227244, September 24, 2002

This is to Certify that  
representative samples of: Component - Systems, Electrical Insulation.  
Class 155(F) insulation systems designated 2-155.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1446 - Systems of Insulating Materials-General  
CSA C22.2 No. 0-M91 - General Requirements - Canadian Electrical  
Code, Part II

Additional Information: Electrical Ratings:

System Designation	Insulation Class	Maximum Temperature	Indoor	Outdoor (Enclosed)	Maximum Voltage
2-155	155 (F)	155°C hot spot	Yes	Yes	600 V

Only those products bearing the UL Recognized Component Markings for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Marking for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: **UL**, may be used in conjunction with the required Recognized Markings. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Marking for Canada consists of the UL Recognized Mark for Canada: **UL** and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory

**LOOK FOR THE UL RECOGNIZED COMPONENT MARKING ON THE PRODUCT**

Engineer: *Roberta Zaffaroni* / R  
Roberta Zaffaroni, Senior Project Engineer  
UL International Italia S.r.l

Review Engineer: *Kenneth J. Grant* / R  
Kenneth J. Grant, Senior Project Engineer  
UL International Italia S.r.l

Pursuant to the Corporate Services Agreement between UL International Italia Srl and Underwriters Laboratories Inc. ("UL"), UL hereby accepts and issues this Certificate of Compliance. For questions in Italy, you may call 079 2636600.